

SHEET NOTES

- 1 NEW SINGLE-PLY MEMBRANE ROOF.
- 2 NEW METAL ROOF OVER RIGID INSULATION OVER VAPOR BARRIER ON TOP OF EXISTING ROOF DECKING.
- 3 NEW METAL COPING ON TOP OF EXISTING CONCRETE PARAPET CAP.
- 4 NEW METAL CAP AND FLASHING ON TOP OF EXISTING CONCRETE CHIMNEY CAP.

A.E. Roger
ARCHITECTS, LL

P.O. Box 34401 • Juneau, Alaska 998
Tele 907.789.7589 Fax 907.789.16



CBJ BLDG. Permit No. BLD2003-00762

CONSTRUCTION DOCUMENTS
Shrine of St. Therese
CHAPEL RENOVATION

Catholic Diocese of Juneau
419 6th Street
Juneau, Alaska 99801


SLAB NOTES

1. REMOVE EXISTING SLAB AND EXCAVATE A MINIMUM OF 4-INCHES BELOW BOTTOM OF NEW SLAB. COMPACT THE BOTTOM OF THE EXCAVATION WITH A MINIMUM OF 6 PASSES WITH A VIBRATORY PLATE COMPACTOR OR A DOUBLE DRUM ROLLER. IF SOFT MATERIAL IS ENCOUNTERED, REMOVE SOFT MATERIAL AND REPLACE WITH D1 GRAVEL.
2. PLACE 10 MIL REINFORCED VAPOR BARRIER OVER COMPACTED MATERIAL.
3. PLACE A 4-INCH LAYER OF D1 GRAVEL OVER VAPOR BARRIER AND COMPACT WITH A MINIMUM OF 6 PASSES OF WALK-BEHIND VIBRATORY PLATE COMPACTOR OR WALK-BEHIND DOUBLE DRUM ROLLER.
4. WALK BEHIND PLATE COMPACTOR SHALL HAVE A MINIMUM WEIGHT OF 1,000 POUNDS AND BE CAPABLE OF DELIVERING A MINIMUM CENTRIFUGAL FORCE OF 10,000 POUNDS. THE WALK-BEHIND DOUBLE-DRUM ROLLER SHOULD HAVE THE CAPABILITY OF DELIVERING A MINIMUM IMPACT FORCE OF 9,500 POUNDS.
5. PLACE 2-INCHES OF RIGID INSULATION. USE EXTRUDED POLYSTYRENE, "UCI FOAMULAR 400" OR APPROVED EQUAL.
6. PLACE 3.5-INCH THICK CONCRETE SLAB WITH NO 3 REBAR AT 18 INCHES ON CENTER EACH WAY. FINISH SLAB WITH STEEL TROWEL. CONCRETE SHOULD HAVE A MINIMUM STRENGTH OF 3,000 PSI AND A MAXIMUM WATER TO CEMENT RATIO OF 0.50.
7. PLACE CONTROL JOINTS AT EACH SIDE OF THE CENTER AISLE AND AT A MAXIMUM SPACING OF 18 FEET ON CENTER PERPENDICULAR TO AISLE. DO NOT OFFSET CONTROL JOINTS OR FORM JOINTS WITH T CONFIGURATION IN PLAN VIEW. DO NOT EXTEND REINFORCING ACROSS CONTROL JOINTS. CONTROL JOINT SHOULD BE EDGED WITH 1/4 INCH RADIUS.

Number	Date	By	Description of Revisions

Sheet Title
NEW WORK
ROOF PLAN

Scale AS SHOWN (11 X 17 = HALF SCALE)
Designed AER Drawn AER
Date DEC. 15, 2003 Checked AER
Approved By AER Job Number 0302



A4 OF 1